

Energy Meter for Residential Installations:

- Simple installations and connectivity
- Type NEMA 3R enclosure for outdoor protection
- Provides high accuracy meter readings
- Communicates over RS485 to provide monitoring data
- Suitable for export limitation, consumption monitoring and StorEdgeTM applications



I Energy Meter with Modbus Connection for North America


SE-MTR240-NN-S-S1


SUPPORTED INVERTERS	SINGLE PHASE INVERTERS		UNITS
ELECTRICAL SERVICE			
AC Input Voltage (Nominal)	2	240	
AC Frequency (Nominal)	60		Hz
Max AC Input Current	100		mA
Connector Type	Terminal ble	Terminal block - 22 to 12	
Grids supported	L1 / L2 / N / PE L1 / L2 / PE		
Power Consumption (Nominal)	3		W
METER ACCURACY (@ 77°F / 25°C, PF:0.7	7-1)		
1 - 100% of Rated Current CT	<u>+</u>	±1.0	
CURRENT TRANSFORMERS ⁽¹⁾			
Nominal Input (at CT Rated Current)	CT1, C	CT1, CT2: 0.333	
Rated RMS current ⁽²⁾	200	400	А
Dimensions (Internal / External)	0.8 x 0.8; 2.4 x 2.4 / 20 x 20; 61 x 61	1.26 x 1.83; 3.3 x 4.5 / 32 x 46.5; 83.4 x 114	in/mm
STANDARD COMPLIANCE			
Safety	UL 1741:2010 Ed.2(Suppl	UL 1741:2010 Ed.2(Supplement SA)+R: 07 Sep 2016	
Emmissions	FCC 47 CFR P	FCC 47 CFR Part 15 Subpart B	
ENVIRONMENTAL			
Operating Temperatures	-40 to +140 / -40 to +60		°F /°C
Relative Humidity (noncondensing)	5	5-90	
Enclosure type	High impact, ABS and/or ABS/PC plastic UL 94V-0, IEC FV-0		
Protection Rating	NEMA Type 3R		
INSTALLATION SPECIFICATIONS			
Dimensions (HxWxD)	8.1 x 12.4 x 4.6 /	8.1 x 12.4 x 4.6 / 206.6 x 316 x 117.5	
Weight	3.9 / 1.8		lb / kg
Conduit Entry Diameters	0.75 or 1 / 19 or 25		in
Mounting Type	Bracket mount		

⁽¹⁾ Current Transformers should be ordered separately: SEACT0750-200NA-20 (200A) or SEACT1250-400NA-20 (400A), 20 per box


⁽²⁾ For other ratings contact SolarEdge

Current Transformer Dimensions





Connecting the Energy Meter



* Current Transformers (CTs) should be ordered separately: SEACT0750-200NA-20 (200A); SEACT1250-400NA-20 (400A). Each comes in boxes of 20.